



## General Fire Safety Checklist

Performing routine fire safety inspections is an integral part of an effective fire prevention and control plan. The following items can be used as a starting point for a fire safety inspection campaign.

Exterior	Yes	No	N/A
Is the facility's address clearly displayed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are there accumulations of combustible materials in outside areas?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is fire exposure from adjoining facilities limited by building separation or fire barriers?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are fire hydrants protected from accidental damage and access to them unobstructed?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are all exterior areas of the business property illuminated?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are exterior doors and windows of the business property secured from unauthorized access?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is the perimeter of the property fenced?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Fire Doors</b>			
Are fire doors free from visible damage?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are fire doors free from obstructions that would prevent closure?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are the areas near fire doors free of combustible material storage that could produce a flash fire (since such a fire could spread through the opening before automatically tripping the door)?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are fusible links of automatic closing mechanisms of fire doors free of paint and other foreign materials?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are the guides and pulleys of automatic closing mechanisms of fire doors free of damage and cables not showing signs of fraying?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<b>Fire Suppression Equipment</b>			
Are fire extinguishers fully charged and checked?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are fire extinguishers conveniently located and readily accessible?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Have fire extinguishers been inspected in the last year?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are fire extinguishers appropriate for the types of hazards present?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Is there a maintenance and service contract for the sprinkler system?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are products, supplies, and equipment that are stored in racks protected by an automatic sprinkler system?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
Are sprinkler heads free of obstructions, with no product, storage, or objects (e.g., beams and ducts) closer than 18 in (457 mm) from the bottom of a sprinkler?	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>



### Fire Alarms

- Are fire alarm zones (areas) clearly marked?
- Is there a maintenance and service contract for the fire alarm system?
- Does the activation of the alarm system cause the release of hold-open devices on smoke compartment doors?
- Does the alarm system include both manual and automatic initiation devices that provide immediate evacuation notification to the occupants?

### Exits, Walkways, Paths, and Aisles

- Are exit doors unlocked when the building is occupied?
- Are means of egress (i.e., aisles to fire exits) clear and unobstructed?
- Are at least two fire exits provided for each smoke compartment?
- Are fire exits provided with panic hardware and not locked, such as by chains and padlocks?
- Are paths to fire protection equipment (e.g., fire alarm control panel) unobstructed?

### Storage

- Are storage rooms, trash rooms, and similar areas separated from other areas by one-hour fire barriers or protected by automatic sprinklers?
- Are compressed gas cylinders stored in a separate area, away from ignition sources, and secured to prevent tipping and damage?
- Are supplies and stock located at least 3 ft (0.9 m) from heating units and ductwork?
- Is the inside storage of flammable or combustible liquids limited so that not more than 120 gal (454 L) of such liquids are stored in any one cabinet and not more than three cabinets located in the same storage area?
- Is the indoor storage of idle wood pallets limited to floor storage not exceeding 6 ft (1.8 m) height and in stacks (of four pallet groups) separated by at least 8 ft (1.4 m), unless the is protected by an appropriately designed automatic sprinkler system?



Yes No N/A

General

- If smoking is allowed on the premises, is it restricted to certain areas and are these non-smoking areas clearly marked?  Yes  No  N/A
- Are emergency telephone numbers conspicuously posted?  Yes  No  N/A
- Do employees check the exit doors and exit paths on a daily basis to ensure egress during an emergency?  Yes  No  N/A

Contact

AIG Programs Loss Control  
 T 800 611 3994  
 F 888 659 9047  
 programslc@aig.com



Bring on tomorrow

The information contained in this publication was obtained from sources believed to be reliable. ISO Services, Inc., its companies and employees make no guarantee of results and assume no liability in connection with either the information herein contained or the safety suggestions herein made. Moreover, it cannot be assumed that every acceptable safety procedure is contained herein or that abnormal or unusual circumstances may not warrant or require further or additional procedure.

American International Group, Inc. (AIG) is a leading international insurance organization serving customers in more than 130 countries. AIG companies serve commercial, institutional, and individual customers through one of the most extensive worldwide property- casualty networks of any insurer. In addition, AIG companies are leading providers of life insurance and retirement services in the United States. AIG common stock is listed on the New York Stock Exchange and the Tokyo Stock Exchange.

Additional information about AIG can be found at [www.aig.com](http://www.aig.com) | YouTube: [www.youtube.com/aig](http://www.youtube.com/aig) | Twitter: @AIG\_LatestNews | LinkedIn: [www.linkedin.com/company/aig](http://www.linkedin.com/company/aig)

AIG is the marketing name for the worldwide property-casualty, life and retirement, and general insurance operations of American International Group, Inc. For additional information, please visit our website at [www.aig.com](http://www.aig.com). All products and services are written or provided by subsidiaries or affiliates of American International Group, Inc. Products or services may not be available in all countries, and coverage is subject to actual policy language. Non-insurance products and services may be provided by independent third parties. Certain property-casualty coverages may be provided by a surplus lines insurer. Surplus lines insurers do not generally participate in state guaranty funds, and insureds are therefore not protected by such funds.