



# 动火作业许可证

在完成此表格之前，请确认此动火作业是否可以有其它的轻风险的作业替代方案，例如移动到室外位置或使用非明火的机械方法进行维修。

第 1 页

<p><b>第 1 部分: 指引</b></p> <ol style="list-style-type: none"> <li>1. 确认所有适用的工作区安全防护措施都已根据本表格（如适用）进行检查并完成。</li> <li>2. 完成第 1 页并保留记录。</li> <li>3. 完成第 2 页，检查动火作业是否符合要求及预防措施完成后，签发给进行动火作业的人员。</li> <li>4. 设施应满足该表中所列指南的要求或当地司法管辖部分的要求（如要求更严格）。</li> <li>5. 每个操作/区域和每个班次只颁发一个许可证。</li> </ol>	<p><b>预防措施检查表</b></p> <p><b>一般的预防措施</b></p> <p><input type="checkbox"/> 若必要，审核作业任务和许可信息及预防措施。</p> <p><input type="checkbox"/> 工作仅限于许可证中指定的区域/设备。</p> <p><input type="checkbox"/> 喷淋保护、消防栓和灭火器均处于正常的待命状态。</p> <p><input type="checkbox"/> 设置了灭火器（或消防软管），所有的消防器材设置在监火区域。</p> <p><input type="checkbox"/> 动火作业设备维护和固定良好（如必需）。</p> <p><b>在工作区 35 英尺（11 米）内:</b></p> <p><input type="checkbox"/> 确认建筑物为不可燃的结构并无可燃覆盖物、绝缘层或夹心材料</p> <p><input type="checkbox"/> 可燃屋顶和地板结构，但采用了防火布或窗帘、金属屏蔽或其他不可燃护罩/隔离保护。</p> <p><input type="checkbox"/> 有可燃夹心板材料的墙、屋顶、地板上禁止任何动火作业。</p> <p><input type="checkbox"/> 所有墙壁和地板开口均已被盖住。</p> <p><input type="checkbox"/> 可燃物已从对面一侧的墙或天花板上清除干净，或需要安排额外的监火人员。</p> <p><input type="checkbox"/> 防火隔离已经设置在作业点正下方，防止火花飞溅。</p> <p><b>在封闭设备上工作:</b></p> <p><input type="checkbox"/> 设备上的所有可燃物均已被清理干净。</p> <p><input type="checkbox"/> 罐体已经过清理，无易燃、可燃的液体、蒸汽或气体。</p> <p><input type="checkbox"/> 压力容器和管道已处于停止运行状态，已被隔离并保持通风。</p> <p><input type="checkbox"/> 储能或电能的设备已处于停止运行状态，并已被隔离。</p> <p><input type="checkbox"/> 工作区气体爆炸下限浓度，如果需要：_____</p> <p><b>监火&amp;监控:</b></p> <p><input type="checkbox"/> 监火需持续在整个动火作业任务中和完成后延续一个小时。</p> <p><input type="checkbox"/> 监火人员接受过灭火器和/或消防栓的使用的培训。</p> <p><input type="checkbox"/> 监火人员接受过作业区域和动火作业风险培训。</p> <p><input type="checkbox"/> 监火人员接受足够的火灾报告培训，能够及时通知从事动火作业的人员，并有权采取必要行动，包括必要时停止工作。</p> <p><input type="checkbox"/> 如果存在会使火花或余烬落下的开口，则在较低楼层应安排监火。 监</p> <p><input type="checkbox"/> 火结束后，继续对动火作业区进行 3 小时的监控。</p>
<p><b>作业人员</b></p> <p>动火作业执行人: <input type="checkbox"/> 员工 <input type="checkbox"/> 承包商</p> <p>姓名: _____</p> <p>作业位置 (建筑/楼层): _____</p>	
<p><b>作业种类:</b></p> <p><input type="checkbox"/> 铜焊 <input type="checkbox"/> 融冻管</p> <p><input type="checkbox"/> 切割 <input type="checkbox"/> 焊接</p> <p><input type="checkbox"/> 打磨 <input type="checkbox"/> 热熔屋面系统作业</p> <p><input type="checkbox"/> 纤焊 <input type="checkbox"/> 燃烧</p> <p><input type="checkbox"/> 其它 _____</p>	
<p><b>批准&amp;跟进</b></p> <p>工作区已全面检查，采取了必要的预防措施，并以获取工作许可： <input type="checkbox"/> 是 <input type="checkbox"/> 否</p> <p>许可证签发人姓名: _____</p> <p>签名: _____</p> <p>许可证签发日期: _____</p> <p>许可证截止日期: _____</p> <p>日期: _____ 时间: _____</p> <p>工作/任务/订单编号: _____</p> <p>许可证编号: _____</p> <p><b>工作结束签名:</b></p> <p>作业人员: _____</p> <p>日期/时间: _____</p> <p>监火人员: _____</p> <p>日期/时间: _____</p> <p>最终确认人员: _____</p> <p>日期/时间: _____</p>	



# 动火作业许可证

在完成此表格之前，请确认此动火作业是否可以有其它的轻风险的作业替代方案，例如移动到室外位置或使用非明火的机械方法进行维修。

**第 2 部分：指引：**

- 作业人员：**在工作区域附近的醒目的位置张贴许可证。完成后，记录日期/时间并通知许可证颁发人或监火人员。
- 监火人员：**完成必须的消防安全检查后，签署许可证并记录消防安全检查完成日期/时间。通知许可证颁发人消防检查已完成。
- 最终检查人员：**进行最终区域安全检查，签署最终完成日期，并从区域中移除许可证并保存记录。

**作业人员**  
 动火作业执行人： 员工  承包商  
 姓名：\_\_\_\_\_  
 作业位置 (建筑/楼层)：\_\_\_\_\_

**作业种类：**

铜焊                       融冻管  
 切割                         焊接  
 打磨                         热熔屋面系统作业  
 纤焊                         燃烧  
 其它 \_\_\_\_\_

**批准&跟进**

工作区已全面检查，采取了必要的预防措施，并准许了这项工作：  
 是  否

许可证签发人姓名：\_\_\_\_\_  
 签名：\_\_\_\_\_  
 许可证签发日期：\_\_\_\_\_  
 许可证截止日期：\_\_\_\_\_  
 日期：\_\_\_\_\_ 时间：\_\_\_\_\_

工作/任务/订单编号：\_\_\_\_\_  
 许可证编号：\_\_\_\_\_

**工作结束签名：**

作业人员：\_\_\_\_\_  
 日期/时间：\_\_\_\_\_  
 监火人员：\_\_\_\_\_  
 日期/时间：\_\_\_\_\_  
 最终确认人员：\_\_\_\_\_  
 日期/时间：\_\_\_\_\_

**预防措施检查表**

**一般的预防措施**

若必要，审核作业任务和许可信息及预防措施。

工作仅限于许可证中指定的区域/设备。

喷淋保护、消火栓和灭火器均处于正常的待命状态。

设置了灭火器（或消防软管），所有的消防器材设置在监火区域。

动火作业设备维护和固定良好（如必需）。

**在工作区 35 英尺（11 米）内：**

确认建筑物为不可燃的结构并无可燃覆盖物、绝缘层或夹心材料。

可燃屋顶和地板结构，但采用了防火布或窗帘、金属屏蔽或其他不可燃护罩/隔离保护。

有可燃夹心板材料的墙、屋顶、地板上禁止任何动火作业。

所有墙壁和地板开口均已被盖住。

可燃物已从对面一侧的墙或天花板上清除干净，或需要安排额外的监火人员。

防火隔离已经设置在作业点正下方，防止火花飞溅。

**在封闭设备上工作：**

设备上的所有可燃物均已被清理干净。

罐体已经过清理，无易燃、可燃的液体、蒸汽或气体。

压力容器和管道已处于停止运行状态，已被隔离并保持通风。

储能或电能的设备已处于停止运行状态，并已被隔离。

工作区气体爆炸下限浓度，如果需要：\_\_\_\_\_

**监火&监控：**

监火需持续在整个动火作业任务和完成后延续一个小时。

监火人员接受过灭火器和/或消防栓的使用的培训。

监火人员接受过作业区域和动火作业风险培训。

监火人员接受足够的火灾报告培训，能够及时通知从事动火作业的人员，并有权采取必要行动，包括必要时停止工作。

如果存在会使火花或余烬落下的开口，则在较低楼层应安排监火监火

结束后，继续对动火作业区进行 3 小时的监控。



## 动火作业许可证

This permit does not purport to set forth all hazards nor to indicate that other hazards do not exist. By providing this permit, neither AIG nor any of its employees make any warranty, express or implied, concerning the use of this permit. Furthermore, neither AIG nor any of its employees shall be liable in any manner (other than liability that may be expressed in any policy of insurance that may be issued by the Company) for personal injury or property damage or loss of any kind arising from or connected with this permit. Reliance upon, or compliance with, any of the information, suggestions or recommendations contained herein or through our hotline in no way guarantees the fulfillment of your obligations under your insurance policy or as may otherwise be required by any laws, rules or regulations. This document is not intended to replace any recommendations from your equipment manufacturers. If you are unsure about any particular testing or maintenance procedure, please contact the manufacturer or your equipment service representative.

American International Group, Inc. (AIG) is a leading global insurance organization. AIG member companies provide a wide range of property casualty insurance, life insurance, retirement solutions, and other financial services to customers in approximately 70 countries and jurisdictions. These diverse offerings include products and services that help businesses and individuals protect their assets, manage risks and provide for retirement security. AIG common stock is listed on the New York Stock Exchange.

Additional information about AIG can be found at [www.aig.com](http://www.aig.com) | YouTube: [www.youtube.com/aig](http://www.youtube.com/aig) | Twitter: [@AIGinsurance](https://twitter.com/AIGinsurance) [www.twitter.com/AIGinsurance](https://twitter.com/AIGinsurance) | LinkedIn: [www.linkedin.com/company/aig](http://www.linkedin.com/company/aig). These references with additional information about AIG have been provided as a convenience, and the information contained on such websites is not incorporated by reference into this document.

AIG is the marketing name for the worldwide property-casualty, life and retirement, and general insurance operations of American International Group, Inc. For additional information, please visit our website at [www.aig.com](http://www.aig.com). All products and services are written or provided by subsidiaries or affiliates of American International Group, Inc. Products or services may not be available in all countries and jurisdictions, and coverage is subject to underwriting requirements and actual policy language. Non-insurance products and services may be provided by independent third parties. Certain property-casualty coverages may be provided by a surplus lines insurer. Surplus lines insurers do not generally participate in state guaranty funds, and insureds are therefore not protected by such funds.

AIG Insurance Company China Limited (AIG China) is a wholly owned subsidiary of American International Group Inc.

© American International Group, Inc. All rights reserved.

COM-CG-09-0078 Hot Work Permit  
Revised: April 18, 2022

# 警告！

动火作业进行中！

小心火灾！

若有任何紧急情况，请联系：

姓名：.....

电话：.....

# 警告！

动火作业许可证

