

Insight: Transformer Monitoring and Testing

Properly monitoring and testing transformers is a key component to understanding transformer health.

Recognizing the Risk

Large Power Transformers (LPTs) are a critical part of the electrical grid. Depending on the system configuration the loss of a single transformer can have a significant impact. Transformer health can be determined with acceptable monitoring and testing which will help identify potential concerns before a catastrophic event.

The rewind or replacement of a failed LPT can take 1-2 years or longer depending on the global constraints. LPTs are also one of the most expensive pieces of equipment in an electrical substation. Considering these two reasons alone it is in the utilities best interest to perform the appropriate monitoring and testing.

Dissolved Gas Analysis

LPTs contain a fluid for the purpose of electrical insulation and heat transfer. Typically, the fluid used is mineral oil, but other fluids such as synthetic esters are also being used. Dissolved gas analysis (DGA) is a method of testing transformer fluid to determine the overall health of a transformer. As the insulating materials within a transformer breakdown due to aging or electrical faults gasses are released into the transformer fluid. Studying and trending DGA samples is a key maintenance practice to determine the health of a transformer.

By measuring and trending these gas concentrations it is possible to narrow down what is happening inside the transformer whether it be normal aging or an internal electrical fault. Also depending on the type of gas generated and the rate that it is generated at it is possible to determine the severity of the issue and allow time to schedule a thorough inspection and take appropriate actions before a trip or a catastrophic event occurs.

DGA has been used for many years and is considered to be the most important maintenance practice for liquid immersed transformers. Over the years as more data is collected and new technologies emerge the interpretation of DGA has become very reliable. In most cases DGA samples can be collected while the transformer is in service as opposed to other testing that requires the transformer to be out of service.

Critical Gasses measured by DGA

Depending on the types of gasses seen and the rate of increase the severity of an electrical fault can be determined. As a fault increases the temperature of the fault increase and corresponding gasses are generated. For a typical DGA sample there are 9 gasses that are measured.

Oxygen – This is typically an indication of air ingress and therefore a leak to atmosphere may be present.

Nitrogen – This is typically an indication of air ingress and therefore a leak to atmosphere may be present. For sealed transformers with a nitrogen blanket a higher concentration may be seen.

Hydrogen – Low energy event that has possible partial discharge activity and/or overheating of fluid.

Methane – Low energy event that has possible partial discharge activity and/or overheating of fluid.

Ethane – Overheating of oil.

Ethylene – Overheating of oil associated with higher temperature overheating.

Carbon Monoxide – Overheating of paper insulation.

Carbon Dioxide – Overheating of paper insulation.

Insight: Transformer Monitoring and Testing

Acetylene – Arcing in oil with very high temperature overheating of oil. Acetylene is generated by arcing and therefore an internal fault is most likely present. Even a very low concentration of acetylene can indicate a severe problem.

Analyzing individual gas concentrations on their own is only one step in understanding DGA. A single gas concentration that is higher than industry standards should be considered as a warning but may not indicate a serious problem based on the history of the transformer. Additional DGA samples are needed to verify an increasing trend and other test methods may be necessary.

Gassing Trends

It is important to perform routine DGA to establish trends and rate increases of these critical gasses. This is important because a significant increase in a key gas may be a concern even though the gas concentration does not exceed the industry standards for that specific sample.

IEEE Std C57.104 is the Guide for the Interpretation of Gases Generated in Mineral Oil-Immersed Transformers and IEEE Std C57.155 should be used for transformers containing ester-based fluid. These standards provide the acceptable limits of individual gasses along with the acceptable rate of change.

Oil Quality and Furan Analysis

Additional oil tests include Oil Quality and Furan Analysis. Oil quality is a good indicator of fluid health and measures Dielectric Strength, Power Factor, Moisture, Color, Interfacial Tension and Acidity. As oil ages and breaks down these parameters will determine if the fluid should be reconditioned.

Furan Analysis indicates the degree of degradation of the transformer paper insulation. As a transformer ages the paper insulation breaks down. If the paper degrades enough it is possible to experience turn-to-turn shorts and eventually complete failure.

Offline Electrical Testing

Routine outages are required to remove the transformer from service and perform offline testing.

- Transformer Power Factor
- Bushing Power Factor and Capacitance
- Transformer Turns Ratio (TTR)
- Insulation Resistance
- Impedance
- Sweep Frequency Response Analysis (SFRA)

Online Monitoring

Continuous online monitoring has become more common, especially for critical LPTs. With new technologies it is now possible to equip transformers with online monitors that provide an even better understanding of transformer health. This real time data can be used to make quick informed decisions. Online monitoring can come in many different levels of monitoring from one single parameter to multiple parameters that populate a sophisticated condition monitoring software platform that uses algorithms to determine overall health.

Bushing monitoring, Dissolved Gas Analysis, and Partial Discharge are a few of the options that utilities are using as part of their online monitoring program. Monitors can be retrofitted onto existing transformers or supplied as part of a new transformer installation.

Insight: Transformer Monitoring and Testing

However, just like the other testing methods that have been discussed, the data gathered needs to be reviewed by a qualified individual and actions taken if deemed necessary.

While online monitoring provides real time data this should not take the place of the other testing and monitoring that is already being performed.

Recommendations

Since not all transformers are as critical as others it is up to the utility to develop a monitoring and testing program that best suits their needs. Dissolved Gas Analysis, Oil Quality, Furan Testing, and Offline testing must be performed at a minimum. Online monitoring provides a great deal of data that can be used to make informed decisions in a relatively quick timeframe and therefore should be considered especially for critical LPTs.

Resources / Standards

The references are:

IEEE Std C57.104 Guide for Interpretation of Gases Generated in Mineral Oil-Immersed Transformers

IEEE Std C57.155 Guide for Interpretation of Gases Generated in Natural Ester and Synthetic Ester-Immersed Transformers

[For more information, contact your local AIG Risk Engineer.](#)

The information, suggestions and recommendations contained herein are for general informational purposes only. This information has been compiled from sources believed to be reliable. Risk Consulting Services do not address every possible loss potential, law, rule, regulation, practice or procedure. No warranty, guarantee, or representation, either expressed or implied, is made as to the correctness or sufficiency of any such service. Reliance upon, or compliance with, any recommendation in no way guarantees any result, including without limitation the fulfillment of your obligations under your insurance policy or as may otherwise be required by any laws, rules or regulations. No responsibility is assumed for the discovery and/or elimination of any hazards that could cause accidents, injury or damage. The information contained herein should not be construed as financial, accounting, tax or legal advice and does not create an attorney-client relationship.

This document is not intended to replace any recommendations from your equipment manufacturers. If you are unsure about any particular testing or maintenance procedure, please contact the manufacturer or your equipment service representative.

American International Group, Inc. (AIG) is a leading global insurance organization. AIG member companies provide a wide range of property casualty insurance, life insurance, retirement solutions and other financial services to customers in approximately 70 countries and jurisdictions. These diverse offerings include products and services that help businesses and individuals protect their assets, manage risks and provide for retirement security. AIG common stock is listed on the New York Stock Exchange.

Additional information about AIG can be found at www.aig.com | YouTube: www.youtube.com/aig | Twitter: [@AIGinsurance](https://twitter.com/AIGinsurance) www.twitter.com/AIGinsurance | LinkedIn: www.linkedin.com/company/aig. These references with additional information about AIG have been provided as a convenience, and the information contained on such websites is not incorporated by reference herein.

AIG is the marketing name for the worldwide property-casualty, life and retirement and general insurance operations of American International Group, Inc. For additional information, please visit our website at www.aig.com. All products and services are written or provided by subsidiaries or affiliates of American International Group, Inc. Products or services may not be available in all countries and jurisdictions, and coverage is subject to underwriting requirements and actual policy language. Non-insurance products and services may be provided by independent third parties. Certain property-casualty coverages may be provided by a surplus lines insurer. Surplus lines insurers do not generally participate in state guaranty funds, and insureds are therefore not protected by such funds.

Copyright © American International Group, Inc. All rights reserved.